
ITEM 1003 - COMBINED SEWERS

Section 1003.01 Combined Sewers Prohibited

The construction of and extension to combined sewers is hereby prohibited.

Section 1003.02 Requirement To Separate Sewers

Individual properties now connected from a point 3 feet outside the building to the public sewer for the purpose of discharging wastes to a combined sewer, may be required, at the individual property owner's expense, to separate sanitary discharges from clearwater discharges beginning at a point 3 feet from the building to the public sewer system whenever such separation is deemed necessary for the public health, welfare and safety, by the Ohio Environmental Protection Agency or the Board.

- END OF ITEM -