



NOTES:

1. CONTRACTOR SHALL PREPARE A FLOW CONTROL PLAN BEFORE CUTTING INTO THE ACTIVE SEWER, SUBMIT TO PORTAGE COUNTY WATER RESOURCES FOR APPROVAL.
2. THE FLEXIBLE COUPLE SHALL HAVE GASKET WITHIN STAINLESS STEEL CLAMP & SHEAR RING MANUFACTURED FOR FLEXIBLE TRANSITION FOR UNDERGROUND PIPING.
3. THE LATERAL CONNECTION SHALL USE A PVC SDR WYE GASKETED FITTING WITH PVC SDR PIPE STUBS USING SDR 35 OR SDR 26 WHEN THE DEPTHS ARE GREATER THAN 12 FEET.
4. WHEN THE FLOW CONTROL OR THE SIZE OF THE EXISTING CUT IN SEWER IS A LIMITING CONDITION, A CAST IRON BODY WITH INTEGRAL PIPE STOP SEWER SADDLE MAY BE USED AS APPROVED BY PORTAGE COUNTY WATER RESOURCES, REQUIRED 3-1/2" STRAP WIDTH, STAINLESS STEEL MATERIALS AND HARDWARE WITH STYRENE BUTADIENE RUBBER GASKET.