



PLAN VIEW

HYDRANT NOTES:

1. SHALL BE GIVEN 2 COATS OF RED HYDRANT ENAMEL, OR AS SPECIFIED IN PCWR SPECIFICATIONS.
2. HYDRANTS SHALL BE FURNISHED WITH (2) 2-1/2" HOSE NOZZLES AND (1) INTEGRAL 4-INCH STORZ NOZZLE.
- 2a. FIRE DEPARTMENTS FOR SHALERSVILLE TWP. AND MANTUA TWP. REQUIRE 5-INCH STORZ NOZZLE.
3. RESTRAINED JOINTS AND BLOCKING REQUIRED TO PREVENT SEPARATION OF JOINTS. METHOD MUST BE APPROVED BY THE ENGINEER.
4. ALL HARDWARE SHALL BE 306 STAINLESS STEEL.
5. ALL VALVES ARE REQUIRED TO OPEN TO THE LEFT IN A COUNTER CLOCKWISE MOTION.
6. HYDRANT SHALL BE MIN. 4' CLEAR OF ANY DRIVE OR VEHICLE PATHWAY.
7. STATIONS, OFFSETS, & ELEVATIONS SHALL BE PROVIDED FOR EACH HYDRANT AND TEE.
8. NO VALVES OR HYDRANTS SHALL BE INSTALLED IN CONCRETE WALKS.
7. ALL CAST IRON WATER MAIN SHALL BE WRAPPED IN POLYETHYLENE.