



#### HYDRANT NOTES:

1. SHALL BE GIVEN 2 COATS OF RED HYDRANT ENAMEL, OR AS SPECIFIED IN PCWR SPECIFICATIONS.
2. HYDRANTS SHALL BE FURNISHED WITH (2) 2-1/2" HOSE NOZZLES AND (1) INTEGRAL 4-INCH STORZ NOZZLE.
- 2a. FIRE DEPARTMENTS FOR SHALERSVILLE TWP. AND MANTUA TWP. REQUIRE 5-INCH STORZ NOZZLE.
3. RESTRAINED JOINTS AND BLOCKING REQUIRED TO PREVENT SEPARATION OF JOINTS. METHOD MUST BE APPROVED BY THE ENGINEER.
4. ALL HARDWARE BOLTS SHALL BE 306 STAINLESS STEEL.
5. ALL VALVES ARE REQUIRED TO CLOSE CLOCKWISE.
6. WEEP HOLES SHALL NOT BE WRAPPED IN POLYETHYLENE ENCASEMENT.
7. ALL CAST IRON WATER MAIN SHALL BE WRAPPED IN POLYETHYLENE.