

PRETREATMENT PROGRAM 2018 ANNUAL REPORT

Streetsboro-Hudson Wastewater Treatment Plant



Portage County Water Resources Department

March 2019

Table of Contents

ANNUAL REPORT CERTIFICATION	3
PRETREATMENT PERFORMANCE SUMMARY.....	4
GENERAL MONITORING INFORMATION.....	5
EXCEPTIONS TO STANDARD MONITORING.....	6
INDUSTRIAL USER INVENTORY AND MONITORING.....	7
INDUSTRIAL INVENTORY MODIFICATIONS.....	14
UPSETS, INTERFERENCES AND PASS-THROUGH INCIDENTS.....	15
PRIORITY POLLUTANT REPORTING FORM.....	16
PRIORITY POLLUTANT LABORATORY RESULTS.....	17
PROGRAM EVALUATION.....	21
1) Approved Program Components.....	21
2) Accomplishments.....	21
3) Problems.....	22
4) Program Modifications.....	22

LIST OF APPENDICES

APPENDIX A	LINKO DATABASE REPORT OF INSPECTIONS COMPLETED, STREETSBORO-HUDSON REGIONAL SYSTEM.....	24
APPENDIX B	LINKO DATABASE REPORT OF SAMPLING COMPLETED.....	26
APPENDIX C	LINKO DATABASE REPORT OF INSPECTIONS COMPLETED, PORTAGE COUNTY REGIONAL SYSTEM.....	28
APPENDIX D	PUBLIC SERVICE ANNOUNCEMENT.....	33



DIVISION OF SURFACE WATER
PRETREATMENT PROGRAM
ANNUAL REPORT CERTIFICATION

March 25, 2019

DATE: _____

SEWER AUTHORITY NAME: Portage County Water Resources (PCWR)

PERIOD COVERED BY REPORT: 1/1/2018 TO: 12/31/2018

WASTEWATER TREATMENT PLANT(S) INCLUDED IN PROGRAM:

NPDES PERMIT NUMBER(S):

Streetsboro-Hudson Regional WWTP

3PK00014*HD

CONTACT PERSON:

NAME: Cindy Hazelett

TITLE: Lab Supervisor/Pretreatment Coordinator

MAILING ADDRESS: 8116 Infirmary Road

Ravenna, Ohio ZIP CODE: 44266

TELEPHONE: (330) 235-7298

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION IN THIS REPORT AND ALL ATTACHMENTS. BASED ON MY INQUIRY OF THOSE PERSONS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION CONTAINED IN THE REPORT, I BELIEVE THAT THE INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT.



SIGNATURE OF OFFICIAL

March 25, 2019

DATE

Director, Portage County Water Resources, P.E.
TITLE

Mail completed reports to:
Ohio EPA, DSW
Pretreatment Unit
P.O. Box 1049, Columbus, Ohio 43216-1049

PRETREATMENT PERFORMANCE SUMMARY

POTW: PCWR, Streetsboro-Hudson Regional WWTP

NPDES PERMIT NO.: 3PK00014*HD

REPORTING PERIOD: 1/1/2018 TO 12/31/2018

TOTAL SIGNIFICANT INDUSTRIAL USERS (SIU's): 1

TOTAL CATEGORICAL INDUSTRIAL USERS: 0

TOTAL SIGNIFICANT NON-CATEGORICAL INDUSTRIAL USERS: 1

COMPLIANCE MONITORING PROGRAM

OF EFFECTIVE CONTROL DOCUMENTS 1

OF SIU's INSPECTED 1

OF SIU's SAMPLED 0

SIGNIFICANT NONCOMPLIANCE ASSESSMENT (SNC)

OF SIU's IN SNC (Categorical/Non-Categorical) 0/0

OF SIU's IN SNC FOR SAMPLING VIOLATIONS 0

OF SIU's IN SNC FOR REPORTING VIOLATIONS 0

OF SIU's IN SNC FOR COMPLIANCE SCHEDULE VIOLATIONS 0

OF NON SIGNIFICANT IU's IN SNC 0

ENFORCEMENT ACTIVITY

OF SHOW-CAUSE HEARINGS 0

OF COMPLIANCE SCHEDULES ISSUED 0

OF ADMINISTRATIVE ORDERS ISSUED 0

OF CIVIL SUITS FILED 0

OF CRIMINAL SUITS FILED 0

AMOUNT OF PENALTIES COLLECTED (Total dollars/# IU's assessed) 0/0

OF FACILITIES IN SNC PUBLISHED (Attach newspaper list) 0

GENERAL MONITORING INFORMATION

POTW: PCWR, Streetsboro-Hudson Regional WWTP

PERIOD COVERED: 1/1/2018 TO 12/31/2018

IU CLASSIFICATION or GENERAL PERMIT NAME	POTW INDUSTRIAL USER MONITORING		INDUSTRIAL USER SELF-MONITORING	
	INSPECTION FREQ	SAMPLING FREQ	SAMPLING FREQ	REPORTING FREQ
Significant Industrial User	Annually	Annually	Quarterly	Quarterly
Non-Significant Industrial User	Bi-Annually	As Required	As Required	As Required
Categorical	Annually	Annually	Bi-monthly	Quarterly
Mid-Tier Categorical	Bi-Annually	Bi-annually	Bi-monthly	Quarterly to Annually
Non-Significant Categorical Interceptor	Bi-Annually Quarterly to Annually	As Required As Required	As Required	As Required Maintain Monthly Monitoring Program

EXCEPTIONS TO STANDARD MONITORING

POTW: PCWR, Streetsboro-Hudson Regional WWTP

PERIOD COVERED: 1/1/2018 TO 12/31/2018

FACILITY NAME & ADDRESS	SIGNIFICANT IU	NONSIGNIFICANT CIU	MID TIER CIU	CATEGORICAL MONITORING WAIVER	LOCAL LIMIT MONITORING WAIVER
International Paper 700 Mondial Parkway Streetsboro, OH 44241	X				The facility submits a quarterly "No Discharge Certification Statement" for process water along with receipts for any waste hauled off site. The facility has begun recycling the majority of their process water. They now also haul some waste off site. This has reduced their daily discharge and we will investigate the possibility of de-listing them from Significant User status. There was no discharge to the sampling manhole after the first quarter, so no sampling was able to be done after that. PCWR personnel did check and found no flow at the manhole.

INDUSTRIAL USER INVENTORY AND MONITORING

POTW: PCWR, Streetsboro-Hudson Regional WWTP PERIOD COVERED: 1/1/2018 TO 12/31/2018

PAGE 1 OF 8

FACILITY NAME & ADDRESS	LOCAL CLASSIFICATION	APPLICABLE STANDARDS	POTW IU MONITORING		IU SELF-MONITORING	
			# OF INSPECTIONS	# SAMPLE EVENTS	# SAMPLE EVENTS	REPORTING FREQUENCY
A. Duie Pyle, Inc 10225 Philipp Parkway	Interceptor	Local				
Action Auto Body 8895 State Route 14	Interceptor	Local				
Aero Mark Inc 10423 Danner Drive	Non-Significant Industrial User	Local				
Air Enterprises Assembly 1777 Miller Parkway	Non-Significant Industrial User	Local				
All Seasons RV Center 9043 State Route 14	Interceptor	Local				
American Heritage Billiards 630 Mondial Parkway	Non-Significant Industrial User	Local				
American Legion 10001 Aurora-Hudson Road	Interceptor	Local				
Americas Best Value Inn 9420 State Route 14	Interceptor	Local				
Ameritech Steel Service Co. 1260 Ethan Avenue	Non-Significant Industrial User	Local				
Applebee's Streetsboro 1200 State Route 303	Interceptor	Local				
AquaTech Inc 1777 Miller Parkway	Non-Significant Industrial User	Local				
Arbors at Streetsboro 1645 Maplewood Drive	Interceptor	Local				
Aurora Plastics 9280 Jefferson Street	Non-Significant Industrial User	Local				
Automated Packaging Systems 600 Mondial Parkway	Interceptor	Local				
Automated Packaging Systems 10175 Philipp Parkway	Non-Significant Industrial User	Local				
Automatic Door Co. 8648 State Route 14	Non-Significant Industrial User	Local				
Avolon Dental 9889 State Route 43	Non-Significant Industrial User	Local				
BASF Construction Chemicals 9658 State Route 43	Non-Significant Industrial User	Local				
Baxter Property Management 10000 Aurora Hudson Road	Interceptor	Local				
Berry PIARIXA (Cardinal Pkg) 1275 Ethan Avenue	Non-Significant Industrial User	Local				
Big Dee's Tack & Vet Supply 9440 State Route 14	Interceptor	Local				
Big Dee's Tack and Vet Supply (Paddock Saddlery) 9998 State Route 43	Non-Significant Industrial User	Local				
Blasioles 9344 State Route 43	Interceptor	Local				
Bob Evans 9361 State Route 14	Interceptor	Local				
Bob's Car Care Center 8900 State Route 14	Interceptor	Local				
Boulder Creek Ltd (Fireside Grill) 9700 Page Road	Interceptor	Local				
Brown Derby Roadhouse 9230 State Route 14	Interceptor	Local				

FACILITY NAME & ADDRESS	LOCAL CLASSIFICATION	APPLICABLE STANDARDS	POTW IU MONITORING		IU SELF-MONITORING	
			# OF INSPECTIONS	# SAMPLE EVENTS	# SAMPLE EVENTS	REPORTING FREQUENCY
BP Gas Station 9202 State Route 14	Interceptor	Local	1			
Building Futures Child Care 9310 Market Square Drive	Interceptor	Local				
Burger King 9535 State Route 14	Interceptor	Local				
BW3 - Buffalo Wild Wings 9062 State Route 14	Interceptor	Local				
Chibi's Dry Cleaner 9268 Market Square Drive	Non-Significant Industrial User	Local				
China Chef 9109 State Route 14	Interceptor	Local				
Chipotle's 9754 State Route 14	Interceptor	Local				
Christine Coven 9143 State Route 14	Interceptor	Local				
Chuggers Bar & Grille 9244 Market Square Drive	Interceptor	Local				
Circle K 9913 State Route 43	Interceptor	Local				
Circle K (Macs Convenience Stores) 1524 State Route 303	Interceptor	Local				
Classic Honda 900 Classic Drive	Interceptor	Local				
Classic Kia 835 Classic Drive	Interceptor	Local				
Cleveland Steel Container Corp. 10048 Aurora-Hudson Road	Non-Significant Industrial User	Local				
Collector's Palace 9274 State Route 43	Retail	Local				
Comfort Inn and Suites 9172 Market Square Drive	Interceptor	Local				
Community Center 1405 Frost Road	Interceptor	Local				
Concession Stand (SSD) 2 Miracle Lane	Interceptor	Local	1			
Crucible Service 3500 Crane Center Drive	Non-Significant Industrial User	Local				
Cycle Leather Outlet 9156 State Route 14	Interceptor	Local				
Dairy Queen (closed) 9081 State Route 14	Interceptor	Local	1			
David Round 10200 Wellman Road	Non-Significant Industrial User	Local				
Defer Tire 955 Singletary Drive	Interceptor	Local				
Delta Systems Inc 1734 Frost Road	Non-Significant Industrial User	Local				
Deluxe Corporation 10030 Philipp Parkway	Non-Significant Industrial User	Local				
Denny's 9449 State Route 14	Interceptor	Local				
Dental Health Associates 9150 Market Square Drive, Suite 103	Non-Significant Industrial User	Local				
Domino's 9380 State Route 43	Interceptor	Local				
Don Patron 9800 State Route 14	Interceptor	Local				

FACILITY NAME & ADDRESS	LOCAL CLASSIFICATION	APPLICABLE STANDARDS	POTW IU MONITORING		IU SELF-MONITORING	
			# OF INSPECTIONS	# SAMPLE EVENTS	# SAMPLE EVENTS	REPORTING FREQUENCY
Dudick Inc 1818 Miller Parkway	Non-Significant Industrial User	Local				
Econo Lodge 9789 State Route 14	Interceptor	Local				
El Campesino's 9169 State Route 14	Interceptor	Local				
Enterprise Rental Car 9773 State Route 14	Interceptor	Local				
Former Giant Eagle 9264 Market Square Drive	Interceptor	Local				
ForTec Medical Inc 10125 Wellman Road	Interceptor	Local				
Fraternal Order of Eagles #4300 9052 State Route 14	Interceptor	Local				
Fresenius Medical Care 9200 Staples Drive	Non-Significant Industrial User	Local				
Fun Buffet 9421 State Route 14	Interceptor	Local				
Geis Construction 10020 Aurora-Hudson Road	Non-Significant Industrial User	Local				
Get Go 9075 State Route 43	Interceptor	Local				
Giant Eagle Streetsboro 1280 State Route 303	Interceptor	Local				
Gionino's Streetsboro 1579 State Route 303	Interceptor	Local				
Great Lakes Hyundai – Svc Dept 9630 State Route 14	Interceptor	Local				
Hammer Company 9450 Rosemont Drive	Non-Significant Industrial User	Local				
Hampton Inn and Suites 800 Mondial Parkway	Non-Significant Industrial User	Local				
Happy Moose 9436 State Route 14	Interceptor	Local				
Holiday Inn Express Hotel & Suites 9459 State Route 14	Interceptor	Local				
Honeybaked Ham (closed) 9354 Market Square Drive	Interceptor	Local				
Horsemen's Pride, Inc 10008 State Route 43	Non-Significant Industrial User	Local				
IHOP 9700 State Route 14	Interceptor	Local				
International Paper 700 Mondial Parkway	Significant Industrial User	Local +MBAS limit	1	0	1	Quarterly
Jbr Construction 10145 Philipp Parkway	Non-Significant Industrial User	Local				
Jims Open Kitchen /Big T' Diner 9086 State Route 14	Interceptor	Local				
Jimyz Automotive Repair 8660 State Route 14	Interceptor	Local				
Joseph Industries, Inc 10039 Aurora-Hudson Road	Non-Significant Industrial User	Local				
KD Computer 1294 State Route 303	Non-Significant Industrial User	Local				
Keep it Moving Auto Sales 8948 State Route 14	Interceptor	Local				
Kids Link Neurobehavioral Ctr 899 Frost Road	Non-Significant Industrial User	Local				

FACILITY NAME & ADDRESS	LOCAL CLASSIFICATION	APPLICABLE STANDARDS	POTW IU MONITORING		IU SELF-MONITORING	
			# OF INSPECTIONS	# SAMPLE EVENTS	# SAMPLE EVENTS	REPORTING FREQUENCY
KFC 9119 State Route 14	Interceptor	Local				
Lafarge 555 Frost Road	Non-Significant Industrial User	Local				
Lange Grinding Inc 10165 Philipp Parkway	Non-Significant Industrial User	Local				
Layman Dental 9330 Market Square Drive	Non-Significant Industrial User	Local				
Little Caesar's Streetsboro 9315 State Route 14	Interceptor	Local				
L'Oréal USA Inc 10345 Philipp Parkway	Non-Significant Industrial User	Local				
McDonalds Streetsboro 9439 State Route 14	Interceptor	Local				
Microbiological Labs Inc 9593 Page Road	Non-Significant Industrial User	Local				
Micro Poise Measurement Systems 555 Mondial Parkway	Interceptor	Local				
Microtel Inn 9371 State Route 14	Interceptor	Local				
Midas 9100 State Route 14	Interceptor	Local				
Millard Refrigerated Service 9300 Jefferson Street	Non-Significant Industrial User	Local				
Mopar Cleveland Parts Distr. Center 9777 Mopar Drive	Non-Significant Industrial User	Local				
Mr. Hero 9229 State Route 14	Interceptor	Local				
NAPA Auto Parts 9011 State Route 14	Non-Significant Industrial User	Local	1			
Natural Essentials, Inc 1800 Miller Parkway	Non-Significant Industrial User	Local	1			
New Peking 9507 State Route 14	Interceptor	Local				
Nissan of Streetsboro 885 Classic Drive	Interceptor	Local				
No Worries In Paradise 9438 SR 14	Interceptor	Local				
North Coast Environmental Laboratories 10100 Wellman Road	Non-Significant Industrial User	Local				
Onex Construction Inc 1430 Miller Parkway	Non-Significant Industrial User	Local				
O'Reilly Auto Parts 9143 State Route 14	Interceptor	Local				
Papa John's Streetsboro 9336 State Route 43	Interceptor	Local				
Permco Inc 1500 Frost Road	Non-Significant Industrial User	Local				
Pin Quest Inc. 10100 Wellman Road	Non-Significant Industrial User	Local				
Pizza Hut Wing Street 9284 State Route 43	Interceptor	Local				
PM Graphics 10170 Philipp Parkway	Non-Significant Industrial User	Local				
Portage Plating 9596 State Route 43	Non-Significant Industrial User	Local				
Quizno's Streetsboro 9517 State Route 14	Interceptor	Local				

FACILITY NAME & ADDRESS	LOCAL CLASSIFICATION	APPLICABLE STANDARDS	POTW IU MONITORING		IU SELF-MONITORING	
			# OF INSPECTIONS	# SAMPLE EVENTS	# SAMPLE EVENTS	REPORTING FREQUENCY
R&T Fence Company 8885 State Route 14	Non-Significant Industrial User	Local				
Ready To Haul 1240 Ethan Avenue	Non-Significant Industrial User	Local				
Reynolds Aluminum Supply Company 3000 Crane Center Drive	Non-Significant Industrial User	Local				
Robinson Health Center 9318 State Route 14	Non-Significant Industrial User	Local				
Rockne's Pub Streetsboro 9406 State Route 14	Interceptor	Local				
Route 14 Plaza 8929 State Route 14	Interceptor	Local				
Ruby Tuesday 9687 State Route 14	Interceptor	Local				
Scher Development LTD 650 Mondial Parkway	Non-Significant Industrial User	Local				
Seegott 10040 Aurora-Hudson Road	Non-Significant Industrial User	Local				
Selas Heat Technology Co. 11012 Aurora-Hudson Road	Non-Significant Industrial User	Local				
Sheetz Streetsboro 9745 State Route 14	Interceptor	Local				
Shell/True North 9536 State Route 14	Interceptor	Local	1			
Solan Industrial Grinding Inc 1400 Miller Parkway	Interceptor	Local				
Sonic 9780 State Route 14	Interceptor	Local				
SOS Trucking 1466 Frost Road	Interceptor	Local				
Special Moments Catering 9127 State Route 14	Interceptor	Local				
Spectrum Diversified Design 675 Mondial Parkway	Non-Significant Industrial User	Local				
Spectrum Machine 1668 Frost Road	Non-Significant Industrial User	Local				
Speedway Streetsboro 9254 State Route 43	Interceptor	Local				
St Lawrence Steel 2500 Crane Center Drive	Non-Significant Industrial User	Local				
Starbucks & Jimmy Johns 9710 State Route 14	Interceptor	Local				
Steak N Shake 9545 State Route 14	Interceptor	Local				
Step2 Company LLC 10010 Aurora-Hudson Road	Non-Significant Industrial User	Local				
Streets Bar 9107 State Route 14 Suite B	Interceptor	Local				
Streetsboro Campus Elementary School 8955 Kirby Lane	Interceptor	Local				
Streetsboro Dental 1727 State Route 303	Non-Significant Industrial User	Local				
Streetsboro Head Start 1880 State Route 303	Interceptor	Local				
Streetsboro Henry Defer Intermediate School 1895 Annalane Drive	Interceptor	Local				

FACILITY NAME & ADDRESS	LOCAL CLASSIFICATION	APPLICABLE STANDARDS	POTW IU MONITORING		IU SELF-MONITORING	
			# OF INSPECTIONS	# SAMPLE EVENTS	# SAMPLE EVENTS	REPORTING FREQUENCY
Streetsboro (Old High School) 1900 Annalane Drive	Interceptor	Local				
Streetsboro High School 8585 State Route 14	Interceptor	Local				
Streetsboro Middle School 1951 Annalane Drive	Interceptor	Local				
Streetsboro Schools Bus Garage 1900 Annalane Drive	Interceptor	Local				
Streetsboro Vet Clinic 9094 State Route 14	Non-Significant Industrial User	Local				
Streetsboro Veterinary Center 9324 State Route 43	Non-Significant Industrial User	Local				
Streetsboro WWTP 9501 Jefferson Street	Non-Significant Industrial User	Local				
Subway SR 14 Streetsboro 9757 State Route 14	Interceptor	Local				
Subway Streetsboro 9380 State Route 43	Interceptor	Local				
Taco Bell 9223 State Route 14	Interceptor	Local				
Target 1144 State Route 303	Interceptor	Local				
Telecon 1677 Miller Parkway	Non-Significant Industrial User	Local				
Teresa's Pizza Streetsboro 9525 State Route 14	Interceptor	Local				
Thai Wah 9160 State Route 14	Interceptor	Local				
Titan's Gym 1543 State Route 303	Interceptor	Local				
Toko Japanese Steakhouse 1619 State Route 303	Interceptor	Local				
Trelleborg Sealing Profiles 1780 Miller Parkway	Non-Significant Industrial User	Local				
Tri Tech Plastics 610 Mondial Parkway	Non-Significant Industrial User	Local				
Ultimate Wash SR 14 9475 State Route 14	Interceptor	Local				
Ultimate Wash SR 43 9901 State Route 43	Interceptor	Local				
Ultimate Wash Streetsboro 8907 State Route 14	Interceptor	Local				
Universal Custom Process Inc 1760 Miller Parkway	Non-Significant Industrial User	Local				
Valvoline Instant Oil Change 9505 State Route 14	Interceptor	Local				
VFW 9434 State Route 43	Interceptor	Local				
Viking Forge Corp 4500 Crane Center Drive	Non-Significant Industrial User	Local				
Walco Organizations 405 Mondial Parkway	Non-Significant Industrial User	Local				
Wallace Computer Services 10400 Danner Drive	Non-Significant Industrial User	Local				
Walmart Streetsboro 905 Singletary Drive	Interceptor	Local				
Wendy's Restaurant 9717 State Route 14	Interceptor	Local				

FACILITY NAME & ADDRESS	LOCAL CLASSIFICATION	APPLICABLE STANDARDS	POTW IU MONITORING		IU SELF-MONITORING	
			# OF INSPECTIONS	# SAMPLE EVENTS	# SAMPLE EVENTS	REPORTING FREQUENCY
Western Reserve Racquet and Fitness Club 11013 Aurora-Hudson Road	Interceptor	Local				
Yarde Metals 10160 Philipp Parkway	Non-Significant Industrial User	Local				
Zip City USA 9960 State Route 43	Interceptor	Local				
INDUSTRIAL USER INVENTORY AND MONITORING PAGE 8 OF 8 POTW: PCWR, Streetsboro-Hudson Regional WWTP PERIOD COVERED: 1/1/2018 TO 12/31/2018						
			POTW IU MONITORING		IU SELF-MONITORING	
			# OF INSPECTIONS	# SAMPLE EVENTS	# SAMPLE EVENTS	REPORTING FREQUENCY
Totals			7	0	1	Quarterly

INDUSTRIAL INVENTORY MODIFICATIONS

POTW: PCWR, Streetsboro-Hudson Regional WWTP

DATE: 1/1/2018 TO 12/31/2018

PAGE 1 OF 1

FACILITY NAME & ADDRESS/ CONTACT PERSON	ADD, CHANGE, DELETE	REASON FOR CHANGE OR DELETION	IF ADDITION OR SIGNIFICANT CHANGE:		FLOW RATE	POLLUTANTS	APPLICABLE STANDARDS
			PROCESS DESCRIPTION	LOCAL CLASSIFICATION			
Arby's 9346 State Route 14	Delete	Out of Business	Restaurant	Interceptor		Oil/Grease/ Sediments	Local
Aribica 9358 Market Square Dr	Delete	Out of Business	Restaurant	Interceptor		Oil/Grease/ Sediments	Local
BP Gas Station 9202 State Route 14	Delete	Out of Business	Gas Station	Interceptor		Oil/Grease/ Sediments	Local
Circle K 9913 State Route 43	Add	Addition to List	Sales	Interceptor		Oil/Grease/ Sediments	Local
Honey Baked Ham 9354 Market Square Dr	Delete	Moved	Food Sales	Interceptor		Oil/Grease/ Sediments	Local

UPSETS, INTERFERENCE AND PASS-THROUGH INCIDENTS

POTW: PCWR, Streetsboro-Hudson Regional WWTP

PERIOD COVERED: 1/1/2018 TO 12/31/2018

PAGE 1 OF 1

TYPE OF INCIDENT	DATE	EXPLANATION/REASON	CORRECTIVE ACTION(S) TAKEN
Minty odor in influent and throughout treatment plant	Occasional	Unknown-looking for industrial source	Natural Essentials returned completed Discharge Disclosure Form. PCWR personnel performed a walk-thru inspection. The facility does smell minty. Will collect samples from nearby manhole for Oil & Grease testing. The facility does use numerous essential oils, etc. in the manufacture of its products.



DIVISION OF SURFACE WATER
PRETREATMENT PROGRAM
PRIORITY POLLUTANT REPORTING FORM

POTW: PCWR, Streetsboro-Hudson Regional WWTP

LABORATORY: Alloway

SAMPLING:	DATE	TIME	
		Start	Stop
INFLUENT	<u>10/3/2018 to 10/4/2018</u>	<u>0815 to 0815</u>	
EFFLUENT	<u>10/3/2018 to 10/4/2018</u>	<u>0800 to 0800</u>	
SLUDGE 1	<u>10/4/2018</u>	<u>0855</u>	
SLUDGE 2	<u>10/4/2018</u>	<u>0850</u>	

SAMPLING LOCATION:

INFLUENT	<u>Influent</u>
EFFLUENT	<u>Effluent</u>
SLUDGE 1	<u>Return Activated Sludge (RAS)</u>
SLUDGE 2	<u>Dryer</u>

HEAVY METALS: Influent Composite, Effluent Composite, Sludge 1 & 2 Composite

ORGANICS:

VOLATILES: Influent & Effluent-Composite
Sludge 1 & 2 Composite

EXTRACTABLES: Influent & Effluent Composite
Sludge 1 & 2 Composite

OTHER: Influent & Effluent-Composite
Sludge 1 & 2 Composite

PERCENT SLUDGE SOLIDS: SLUDGE 1 0.62 SLUDGE 2 93.3

COMMENTS:

POTW PRETREATMENT CONTACT:

Cindy L. Hazelett, Laboratory Supervisor/IPP Coordinator
Name and Title (please print)

Cindy L. Hazelett
Signature

March 25, 2019
Date

Priority Pollutant Reporting - Data Entry Spreadsheet

Permit Number

3PK00014*HD

Facility Name

Streetsboro WWTP

Pollutant	Pollutant ID	CAS #	Influent (Ug/L)	Effluent (Ug/L)	Sludge 1 RAS (mg/kg Dry)	Sludge 2 Dryer (mg/kg Dry)
Heavy Metals						
Antimony	12182	7440-36-0	AA 5	AA 5	AA 16.0	1.8
Arsenic	12183	7440-38-2	AA 5	AA 5	AA 16.0	8.88
Beryllium	12184	7440-41-7	AA 3	AA 3	AA 9.62	AA 0.320
Cadmium	12185	7440-43-9	AA 3	AA 3	AA 16.0	0.701
Chromium	12186	7440-47-3	AA 7	AA 7	51.4	69.2
Copper	12187	7440-50-8	53	AA 8	283	499
Lead	12188	7439-92-1	AA 10	AA 10	AA 32.1	21.8
Mercury	12189	7439-97-6	0.0100	AA 0.0005	AA 16.1	0.561
Molybdenum	12117	7439-98-7	AA 20	AA 20	AA 64.2	13.1
Nickel	12190	7440-02-0	AA 8	AA 8	AA 32.1	21.3
Selenium	12191	7782-49-2	AA 4	AA 4	AA 16.0	AA 3.14
Silver	12192	7440-22-4	AA 5	AA 5	AA 16.0	3.18
Thallium	12193	7440-28-0	AA 5	AA 5	AA 16.0	AA 0.534
Zinc	12194	7440-66-6	95	27	357	645
Volatiles						
Acrolein	12198	107-02-08	AA 50.0	AA 50.0	AA 40.2	AA 0.268
Acrylonitrile	12199	107-13-1	AA 50.0	AA 50.0	AA 20.1	AA 0.134
Benzene	12200	71-43-2	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Bromoform	12202	75-25-2	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Carbon Tetrachloride	12203	56-23-5	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Chlorobenzene	12204	108-90-7	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Chlorodibromomethane	12205	124-48-1	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Chloroethane	12206	75-00-3	AA 10.0	AA 10.0	AA 4.03	AA 0.0268
2-Chloroethyl Vinyl Ether	12207	110-75-8	AA 10	AA 10	AA 4.03	AA 0.0268
Chloroform	12208	67-66-3	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Dichlorobromomethane	12209	75-27-4	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
1,1-Dichloroethane	12211	75-34-3	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
1,2-Dichloroethane	12212	107-06-2	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
1,1-Dichloroethylene	12213	75-35-4	AA 5.0	AA 5.0	AA 2.09	AA 0.0139

1,2-Dichloropropane	12214	78-87-5	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
1,3-Dichloropropylene	12215	542-75-6	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Ethylbenzene	12216	100-41-4	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Methyl Bromide	12217	74-83-9	AA 10.0	AA 10.0	AA 10.0	AA 4.03	AA 0.0268
Methyl Chloride	12218	74-87-3	AA 10	AA 10	AA 10	AA 4.03	AA 0.0268
Methylene Chloride	12219	75-09-2	AA 10	AA 10	AA 10	AA 32.2	AA 0.214
1,1,2,2-Tetrachloroethane	12220	79-34-5	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Tetrachloroethylene	12221	027-18-4	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Toluene	12222	108-88-3	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
1,2-Trans-Dichloroethylene	12223	156-60-5	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
1,1,1-Trichloroethane	12224	71-55-6	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
1,1,2-Trichloroethane	12225	79-00-5	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Trichloroethylene	12226	79-01-6	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
Vinyl Chloride	12228	75-01-4	AA 10	AA 10	AA 10	AA 4.03	AA 0.0268
Base Neutrals							
Acenaphthene	12275	83-32-9	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Acenaphthylene	12276	208-96-8	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Anthracene	12277	120-12-7	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Benzidine	12278	92-87-5	AA 50.0	AA 50.0	AA 50.0	AA 805	AA 5.35
Benzo (A) Anthracene	12279	56-55-3	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Benzo (A) Pyrene	12280	50-32-8	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
3,4-Benzofluoranthene	12281	205-99-2	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Benzo (GHI) Perylene	12282	191-24-2	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Benzo (K) Fluoranthene	12283	207-08-9	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Bis (2-Chloroethoxy) Methane	12284	111-91-1	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Bis (2-Chloroethyl) Ether	12285	111-44-4	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Bis (2-Chloroisopropyl) Ether	12286	108-60-1	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Bis (2-Ethylhexyl) Phthalate	12287	117-81-7	7.1	7.1	AA 5.0	AA 161	8.21
4-Bromophenyl phenyl Ether	12288	101-55-3	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Butyl Benzyl phthalate	12289	85-68-7	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
2-Chloronaphthalene	12290	91-58-7	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
4-Chlorophenyl Phenyl Ether	12291	7005-72-3	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Chrysene	12292	218-01-9	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Dibenzo (A,H) Anthracene	12293	53-70-3	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
1,2-Dichlorobenzene	12294	95-50-1	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
1,3-Dichlorobenzene	12295	541-73-1	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
1,4-Dichlorobenzene	12440	106-46-7	AA 5.0	AA 5.0	AA 5.0	AA 2.09	AA 0.0139
3,3-Dichlorobenzidine	12441	91-94-1	AA 20.0	AA 20.0	AA 20.0	AA 322	AA 0.0139

Diethyl Phthalate	12442	84-66-2	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Dimethyl Phthalate	12443	131-11-3	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Di-N-Butyl Phthalate	12444	84-74-2	AA 10.0	AA 10.0	AA 10.0	AA 322	AA 2.14
2,4-Dinitrotoluene	12445	121-14-2	AA 20.0	AA 20.0	AA 20.0	AA 322	AA 2.14
2,6-Dinitrotoluene	12446	606-20-2	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Di-N-Octyl Phthalate	12447	117-84-0	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
1,2-Diphenylhydrazine	12448	122-66-7	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Fluoranthene	12449	206-44-0	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Fluorene	12450	86-73-7	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Hexachlorobenzene	12451	118-74-1	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Hexachlorobutadiene	12452	87-68-3	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Hexachlorocyclopentadiene	12453	77-47-4	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Hexachloroethane	12454	67-72-1	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Indeno (1,2,3-CD) Pyrene	12455	193-39-5	AA 20.0	AA 20.0	AA 20.0	AA 322	AA 2.14
Isophorone	12456	78-59-1	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Naphthalene	12457	91-20-3	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Nitrobenzene	12458	98-95-3	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
N-Nitrosodimethylamine	12459	62-75-9	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
N-Nitrosodi-N-Propylamine	12460	621-64-7	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
N-Nitrosodiphenylamine	12461	86-30-6	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Phenanthrene	12462	85-01-8	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
Pyrene	12463	129-00-0	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
1,2,4-Trichlorobenzene	12464	120-82-1	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
2-Chlorophenol	12264	95-57-8	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
2,4-Dichlorophenol	12265	120-83-2	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
2,4-Dimethylphenol	12266	105-67-9	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
4,6-Dinitro-O-Cresol	12267	534-52-1	AA 50.0	AA 50.0	AA 50.0	AA 805	AA 5.35
2,4-Dinitrophenol	12268	51-28-5	AA 50.0	AA 50.0	AA 50.0	AA 161	AA 5.35
2-Nitrophenol	12269	88-75-5	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
4-Nitrophenol	12270	100-02-7	AA 50.0	AA 50.0	AA 50.0	AA 805	AA 5.35
p-Chloro-M-Cresol	12271	59-50-7	AA 50.0	AA 50.0	AA 50.0	AA 805	AA 5.35
Pentachlorophenol	12272	87-86-5	AA 50.0	AA 50.0	AA 50.0	AA 805	AA 5.35
Phenol	12273	108-95-2	AA 10.0	AA 10.0	AA 10.0	AA 161	AA 1.07
2,4,6-Trichlorophenol	12274	88-06-2	AA 20.0	AA 20.0	AA 20.0	AA 322	AA 2.14
Pesticides							
Aldrin	12465	309-00-2	AA 0.25	AA 0.25	AA 0.25	AA 1.62	AA 0.54
Alpha-BHC	12466	319-84-6	AA 0.25	AA 0.25	AA 0.25	AA 1.62	AA 0.54
Beta-BHC	12467	319-85-7	AA 0.25	AA 0.25	AA 0.25	AA 1.62	AA 0.54

Delta-BHC	12468	319-86-8	AA 0.25	AA 0.25	AA 1.62	AA 0.54
Gamma-BHC	12469	58-89-9	AA 0.25	AA 0.25	AA 1.62	AA 0.54
Chlordane	12470	57-74-9	AA 0.50	AA 0.50	AA 8.10	AA 2.70
4,4-DDT	12471	50-29-3	AA 0.50	AA 0.50	AA 1.62	AA 0.54
4,4-DDE	12472	72-55-9	AA 0.50	AA 0.50	AA 1.62	AA 0.54
4,4-DDD	12473	72-54-8	AA 0.50	AA 0.50	AA 1.62	AA 0.54
Dieldrin	12474	60-57-1	AA 0.50	AA 0.50	AA 1.62	AA 0.54
Alpha Endosulfan	12475	959-98-8	AA 0.25	AA 0.25	AA 1.62	AA 0.54
Beta Endosulfan	12476	33213-65-9	AA 0.50	AA 0.50	AA 1.62	AA 0.54
Endosulfan Sulfate	12477	1031-07-08	AA 0.50	AA 0.50	AA 1.62	AA 0.54
Endrin	12478	72-20-8	AA 0.50	AA 0.50	AA 1.62	AA 0.54
Endrin Aldehyde	12479	7421-93-4	AA 0.50	AA 0.50	AA 1.62	AA 0.54
Heptachlor	12480	76-44-8	AA 0.25	AA 0.25	AA 1.62	AA 0.54
Heptachlor Epoxide	12481	1024-57-3	AA 0.25	AA 0.25	AA 1.62	AA 0.54
PCB-1242	12482	53469-21-9	AA 5.00	AA 5.00	AA 16.2	AA 5.40
PCB-1254	12483	11097-69-1	AA 5.00	AA 5.00	AA 16.2	AA 5.40
PCB-1221	12484	11104-28-2	AA 5.00	AA 5.00	AA 16.2	AA 5.40
PCB-1232	12485	11141-16-5	AA 5.00	AA 5.00	AA 16.2	AA 5.40
PCB-1248	12486	12672-29-6	AA 5.00	AA 5.00	AA 16.2	AA 5.40
PCB-1260	12487	11096-82-5	AA 5.00	AA 5.00	AA 16.2	AA 5.40
PCB-1016	12488	12674-11-2	AA 5.00	AA 5.00	AA 16.2	AA 5.40
Toxaphene	12489	8001-35-2	AA 12.5	AA 12.5	AA 64.8	AA 21.6
Others						
Cyanide, Total	12195	57-12-5	AA 10	AA 10	AA 80.2	4.87
Hardness (as CaCO3)	12500	471-34-1	520000	460000	0	0
Total Phenolic Compounds	12501		80	AA 50	0	0

1,2-, 1,3-, and 1,4-dichlorobenzene- Influent and effluent analyzed by EPA Method 624 per 40 CFR part 136; sludge analyzed by SW 8260B

PROGRAM EVALUATION

1) Approved Program Components:

a) Review of changes to State and/or Federal pretreatment regulations during the past year:

The Dental Amalgam Rule went into effect (2017). Required mailings have been sent to area dentists discharging into County owned systems.

b) Review of the adequacy of the sewer use ordinance.

All aspects of the approved pretreatment program are included in the current sewer use ordinance.

c) Review of operating procedures of the pretreatment program.

PCWR currently utilizes the LINKO database to maintain the schedules for sampling events, inspections, sample results, permitting, contact information, and notes.

d) Discussion of method of funding the pretreatment program and annual budget.

PCWR's pretreatment program is currently funded through Streetsboro WWTP and Portage County WWTP general funds and interceptor fees. Staff hours are tracked on time sheets. PCWR adds \$25 per quarter to bills for each interceptor.

e) Review of adequacy of local limits.

The limits appear to be adequate at this time.

2) Accomplishments:

- a) Although not required by permit, PCWR does maintain a database of IU's in all its systems, in addition to Streetsboro, and charges Sewer Interceptor Use Fees where appropriate. Inspections and sampling are also done throughout all our systems. (See Appendix A for inspections in the Streetsboro system and Appendix C for inspections in other systems.) Those records are maintained in our offices in the LINKO database and as paper files. Because of the way the dates fell for the inspection rotations, many facilities in the Streetsboro system were not inspected during 2018. They were inspected early in the calendar year of 2019 and records are on file at this office and will be included with next year's report.

- b) PCWR successfully completed an Industrial Pretreatment Program Compliance Inspection on September 21, 2018 conducted by Donna Kniss of the Northeast District Office of Ohio EPA. The overall evaluation of the program was good with some minor deficiencies to be addressed.
- c) PCWR developed and implemented a Propriety Information Policy to protect any customers who divulge such information. Proprietary information is stored in a fire proof lock box in the office of the Industrial Pretreatment Coordinator. Access is by a key that is kept by the Coordinator. A spare key is kept by the Administrative Assistant.
- d) PCWR posted an informational Public Service Announcement (Appendix D) on its website about the harmful effects of Fats, Oil, and Grease (FOG) and wet wipes to the sewer systems. The intent is to post a new educational blurb on a regular basis.
- e) PCWR developed and implemented a Fats, Oils, and Grease Disclosure Form. This form is geared toward food service establishments to help determine the nature of their discharges and the potential for concern.
- f) The PCWR Industrial Pretreatment Program (IPP) Coordinator is an active member of the Portage County Local Emergency Planning Committee (LEPC), in part, to be aware of spills which may occur in sewered areas. The IPP Coordinator is a member of the group's Public Education Committee. A table top emergency exercise was put on by the LEPC in 2018 and attended by the IPP Coordinator, simulating a chlorine leak at Nestle Ryder which is located very near to the Streetsboro WWTP.
- g) PCWR participated in a Pharmaceutical Collection Event, in cooperation with the Portage County Sheriff, Health Department, Solid Waste District, and federal Drug Enforcement Agency (DEA) on April 28 and October 27 of 2018. This service collects prescription drugs for removal from the wastewater stream for proper disposal.

3) Problems:

The Streetsboro-Hudson Regional WWTP does experience occasional bouts of a minty odor occurring in the influent flow to the plant and travelling throughout the treatment plant. We are continuing to investigate various possible sources. Sampling will begin next week (week of March 25, 2019) to attempt to document the cause.

4) Program Modifications:

There are no additional program modifications to report at this time.

APPENDIX A

LINKO DATABASE REPORT ON INSPECTIONS COMPLETED

Streetsboro-Hudson Regional WWTP

Streetsboro-Hudson Regional Inspections

Industry No	Industry Name	Site Address	Zip Code	Event Type	Event Category	Due Date	Completed Date	Performed By	Event Comments
ST-4 1002	BP Gas Station/7-Eleven	9202 State Route 14	44241	FOG	INSPECTION	27-Aug-18	27-Aug-18	hcarpenter	FOG Inspection
ST-4 712	Concession Stand (SSD)	2 Miracle Lane	44241	FOG	INSPECTION	27-Aug-18	27-Aug-18	hcarpenter	FOG Inspection
ST-4-1 479	Dairy Queen Streetsboro (closed)	9081 State Route 14	44241	ANNUAL	INSPECTION	26-Sep-18	26-Sep-18	hcarpenter	An annual inspection
ST-4 674	International Paper	700 Mondial Parkway	44241	ANNUAL	INSPECTION	11-Dec-18	09-Nov-18	chazelett	An annual inspection
ST-4 329	NAPA Auto Parts	9011 State Route 14	44241	FOG	INSPECTION	27-Aug-18	27-Aug-18	hcarpenter	FOG Inspection
ST-4 467	Natural Essentials, Inc	1800 Miller Parkway	44241	ANNUAL	INSPECTION	12-Apr-18	12-Apr-18	chazelett	An annual inspection
ST-4 617	Shell/True North	9354 State Route 14	44241	FOG	INSPECTION	27-Aug-18	27-Aug-18	hcarpenter	FOG Inspection

APPENDIX B

LINKO DATABASE REPORT ON POTW SAMPLING COMPLETED

Streetsboro-Hudson Regional WWTP

Streetsboro-Hudson Regional Sampling Events									
Industry No	Industry Name	Site Address	Zip Code	Event Type	Event Category	Due Date	Completed Date	Performed By	Event Comments
ST-4 674	International Paper	700 Mondial Parkway	44241	IU_SAMPLE	SAMPLE	31-Mar-18	15-Feb-18	Industrial User	Sample collected by Industrial User
ST-4 WWTP	Streetsboro Wastewater Treatment Plant	9501 Jefferson Street	44241	AUTH_SAMPLE	SAMPLE	31-Aug-18	04-Oct-18	jakerley	Auto Scheduled by: ST-4 WWTP AUTH_SAMP 9/1/2015 Sample collected by POTW personnel

APPENDIX C

LINKO DATABASE REPORT ON INSPECTIONS COMPLETED

Portage County Regional WWTP's

Portage County Regional Inspections									
Industry No	Industry Name	Site Address	Zip Code	Event Type	Event Category	Due Date	Completed Date	Performed By	Event Comments
RO 1114	Arby's Rootstown	4231 Lynn Rd	44272	FOG	INSPECTION	02-Jan-18	02-Jan-18	hcarpenter	FOG Inspection
RO-31	BP Gas Station Rootstown	4471 St Rt 44	44266	FOG	INSPECTION	23-Jan-18	23-Jan-18	hcarpenter	FOG Inspection
BR-2 469 A	Brimfield Bread Oven	3958 St Rt 43	44240	FOG	INSPECTION	08-Aug-18	13-Feb-19	jworkman	FOG Inspection
BR-2 332	Brimfield Family Restaurant	1198 Tallmadge Rd	44240	FOG	INSPECTION	08-Aug-18	12-Feb-19	jworkman	FOG Inspection
BR-2 183	Brimfield Fire Station	1333 Tallmadge Rd	44240	FOG	INSPECTION	20-Dec-18	08-Feb-19	jworkman	FOG Inspection
RO 77_1	Caporaletti's Pizza	4260 St Rt 44	44272	FOG	INSPECTION	02-Jan-18	02-Jan-18	hcarpenter	FOG Inspection
MA-1 4	Carlton-Harley Davidson	11771 St Rt 44	44255	ANNUAL	INSPECTION	23-Jan-18	23-Jan-18	hcarpenter	An annual inspection
RO 112_1	China Dragon	4143 Tallmadge Rd	44722	ANNUAL	INSPECTION	05-Jan-18	05-Jan-18	hcarpenter	An annual inspection
RO 654	Circle K Rootstown	4307 St Rt 44	44272	FOG	INSPECTION	03-Jan-18	03-Jan-18	hcarpenter	FOG Inspection
RO 654	Circle K Rootstown	4307 St Rt 44	44272	ANNUAL	INSPECTION	28-Dec-18	28-Dec-18	hcarpenter	An annual inspection
RO 1125	Cracker Barrel	4367 St Rt 44	44272	FOG	INSPECTION	02-Jan-18	02-Jan-18	hcarpenter	FOG Inspection
MA-135	DSI Bulk Transport	9893 St Rt 44	44255	ANNUAL	INSPECTION	23-Jan-18	23-Jan-18	hcarpenter	An annual inspection
RO 737	Firehouse Grill & Pub	4809 S. Prospect	44266	ANNUAL	INSPECTION	02-Jan-18	02-Jan-18	hcarpenter	An annual inspection
RO 77_2	Giant Eagle Rootstown	4260 St Rt 44	44166	FOG	INSPECTION	02-Jan-18	02-Jan-18	hcarpenter	FOG Inspection

Portage County Regional Inspections									
Industry No	Industry Name	Site Address	Zip Code	Event Type	Event Category	Due Date	Completed Date	Performed By	Event Comments
BR-2 193	Gionino's Pizzeria Brimfield	4081 St Rt 43	44241	FOG	INSPECTION	08-Aug-18	08-Feb-19	jworkman	FOG Inspection
RO 321_2	Horning's Diversified Inv. Group Inc. (Car Wash)	4500 St Rt 44	44266	ANNUAL	INSPECTION	04-Jan-18	04-Jan-18	hcarpenter	An annual inspection
BR-2 427	Hydrosol System 4175	4216 & 4175 Karg Industrial Parkway	44240	ANNUAL	INSPECTION	25-May-18	25-Jan-18	jworkman	An annual inspection. Trap at 4175 is not in use as of yet. Traps at 4216 needs cleaned asap.
BR-2 427	Hydrosol System 4175	4216 & 4175 Karg Industrial Parkway	44240	Follow-Up	INSPECTION	01-Mar-18	01-Mar-18	chazelett	Follow-up Inspection. Business is to provide Priority Pollutant Scan, Phosphorus, and O&G results before a determination is made.
BR-3 5	Kent BP Company	4415 St Rt 43	44240	FOG	INSPECTION	18-Jul-18	13-Feb-19	jworkman	FOG Inspection
FR-1 309	La Terraza Mexican Bar & Grill	1888 St Rt 59	44240	FOG	INSPECTION	11-Jan-18	11-Jan-18	jworkman	FOG Inspection. Trap lids are not watertight.
BR-2 595	Lauren Manufacturing	4211 Karg Industrial Parkway	44240	ANNUAL	INSPECTION	12-Jun-18	12-Jun-18	chazelett	An annual inspection
MA-1 13	Mantua Corners Bar & Grille	11697 St Rt 44	44255	ANNUAL	INSPECTION	24-Jan-18	24-Jan-18	hcarpenter	An annual inspection
RO 32	McDonalds Rootstown	4190 Lynn Rd	44266	ANNUAL	INSPECTION	28-Dec-18	28-Dec-18	hcarpenter	An annual inspection
RO 32	McDonalds Rootstown	4190 Lynn Rd	44266	ANNUAL	INSPECTION	11-Jan-18	11-Jan-18	hcarpenter	An annual inspection
RO 97	NEOMED	4209 St Rt 44	44272	FOG	INSPECTION	03-Jan-18	03-Jan-18	hcarpenter	FOG Inspection

Portage County Regional Inspections

Industry No	Industry Name	Site Address	Zip Code	Event Type	Event Category	Due Date	Completed Date	Performed By	Event Comments
RO 1121	New Milford Café	4927 Greenwood Rd	44272	ANNUAL	INSPECTION	05-Jan-18	05-Jan-18	hcarpenter	An annual inspection
RO 1236	Noah's Ark Child Care, Inc	4524 Lynn Rd	44272	ANNUAL	INSPECTION	04-Jan-18	04-Jan-18	hcarpenter	An annual inspection
RO 1236	Noah's Ark Child Care, Inc	4524 Lynn Rd	44272	ANNUAL	INSPECTION	28-Dec-18	28-Dec-18	hcarpenter	An annual inspection
MA-1 106	Ohio Turnpike - Brady's Leap Plaza	9250 Limeridge Rd (South Side)	44255	FOG	INSPECTION	27-Aug-18	27-Aug-18	hcarpenter	FOG Inspection 2-2.5 inches of grease present. Hauling records were not readily available. Troy says will send to us. Said interceptors hauled about every 6 weeks. Requested pumping slips in follow up letter to inspection sent on 8/30/2018.
MA-1 107	Ohio Turnpike - Brady's Leap Plaza	9270 Limeridge Rd (North side)	44255	FOG	INSPECTION	27-Aug-18	27-Aug-18	hcarpenter	FOG Inspection Grease about 6 inches thick. Pumping needed soon. Pumping logs not readily available. Troy will send. Requested pumping slips in follow up letter to inspection sent on 8/30/2018.
FR-1 1340B	PARTA	2000 Summit Rd	44240	FOG	INSPECTION	15-Aug-18	08-Jan-19	chazelett	FOG Inspection
BR-2 686	Pep's Car Wash	1385 Tallmadge Rd	44240	FOG	INSPECTION	20-Dec-18	13-Feb-19	jworkman	FOG Inspection Need to receive records of cleanings
BR-2 1495	Pizza Hut Brimfield	4118 St Rt 43	44240	FOG	INSPECTION	03-Aug-18	13-Feb-19	jworkman	FOG Inspection
RO 102	Portage Meats and Deli	4161 Tallmadge Rd	44272	ANNUAL	INSPECTION	11-Jan-18	11-Jan-18	hcarpenter	An annual inspection
BR-2 342	Rico's	1332 Tallmadge Rd	44240	FOG	INSPECTION	20-Dec-18	13-Feb-19	jworkman	FOG Inspection

Portage County Regional Inspections									
Industry No	Industry Name	Site Address	Zip Code	Event Type	Event Category	Due Date	Completed Date	Performed By	Event Comments
RO 321_1	Rootstown School Bus Garage	4255 Tallmadge Rd	44272	ANNUAL	INSPECTION	11-Jan-18	11-Jan-18	hcarpenter	An annual inspection
RO 753B	Rootstown Twp. Fire Dept	4152 Tallmadge Rd	44272	ANNUAL	INSPECTION	11-Jan-18	11-Jan-18	hcarpenter	An annual inspection
RO 2234	Rootstown Twp. Trustees Garage	3988 St Rt 44	44272	ANNUAL	INSPECTION	11-Jan-18	11-Jan-18	hcarpenter	An annual inspection
MA-1 1	Scotty's Shop	4838 St Rt 82	44255	ANNUAL	INSPECTION	24-Jan-18	24-Jan-18	hcarpenter	An annual inspection
RO 29	Speedway Rootstown	4162 Lynn Rd	44272	ANNUAL	INSPECTION	28-Dec-18	28-Dec-18	hcarpenter	An annual inspection
RO 29	Speedway Rootstown	4162 Lynn Rd	44272	ANNUAL	INSPECTION	03-Jan-18	03-Jan-18	hcarpenter	An annual inspection
MA-1 7	Subwrap	4737 St Rt 82	44255	ANNUAL	INSPECTION	24-Jan-18	24-Jan-18	hcarpenter	An annual inspection
MA-1 21	T L Express Inc	4626 St Rt 82	44255	ANNUAL	INSPECTION	23-Jan-18	23-Jan-18	hcarpenter	An annual inspection
MA-1 24	Teresa's Pizza Mantua	11651 St Rt 44	44255	ANNUAL	INSPECTION	24-Jan-18	24-Jan-18	hcarpenter	An annual inspection
BR-3 640	Terri's Towing Kwik Lube	4554 St Rt 43	44240	FOG	INSPECTION	26-Dec-18	13-Feb-19	jworkman	FOG Inspection Business was closed. Knapp's Collision is coming soon. No one was on the property, only a new sign. FOG Inspection
BR-2 173	Van's Tire & Brake Center	4260 St Rt 43	44240	FOG	INSPECTION	05-Apr-18	13-Feb-19	jworkman	FOG Inspection
RO 313	Wendy's (Rootstown)	4151 Lynn Rd	44266	ANNUAL	INSPECTION	11-Jan-18	11-Jan-18	hcarpenter	An annual inspection
RO 313	Wendy's (Rootstown)	4151 Lynn Rd	44266	ANNUAL	INSPECTION	28-Dec-18	28-Dec-18	hcarpenter	An annual inspection
BR-2 617	Wendy's Brimfield	4244 St Rt 43	44240	FOG	INSPECTION	08-Aug-18	12-Feb-19	jworkman	FOG Inspection

APPENDIX D

Public Service Announcement

Did You Know...

When you flush things down the toilet or sink, they do not just “disappear” into the sewer lines. Flushing of inappropriate items may cause a blockage in the sewer lines resulting in a backup in your home or that of your neighbors farther down the line.

Our staff is seeing problems for two main items of concern recently.

1. Fats, oil, and grease (FOG) that solidify in sewer lines and cause blockages. One of the largest of this type of blockages on record was a 130 ton “fatberg” that formed in the London sewers. It took an eight-person crew, working around the clock, days to clear this blockage according to various news reports. The solid blockage was composed of cooking fat and wet wipes which brings us to the second item of concern...
2. Wet wipes also play a part in many sewer blockages. Even those marketed as flushable, rather than just disposable, don’t break down fast enough to prevent problems in the sewer system. And some wipes contain alcohol and/or enzymes that can have even more negative effects.



Grease in sewer, Portage County, Ohio, Rootstown area.



Same line after cleaning

The lesson to be learned is “Not everything that can be flushed, should be flushed”. First, think about if the item in question can make it all the way to the sewer plant without harming the treatment system. Think before you flush!

