

- 1. CURB BOXES SHALL BE LOCATED ON R/W LINE.
- 2. WATER SERVICE TAPS SHALL BE 1" IN SIZE
- 3. ALL WATER SERVICE LINES THROUGH CURB BOX SHALL BE HYDROSTATICALLY TESTED WITH NEW WATERMAN.
- 4. CURB BOXES SHALL NOT BE LOCATED IN DRIVEWAYS OR SIDEWALKS
- 5. CURB BOX SHALL BE SET PLUM & CENTERED ON CURB STOP
- 6. CURB BOX ROD SHALL NOT BE USED UNLESS DEPTH IS GREATER THAN 7'
- 7. IF SERVICE ON PRIVATE SIDE IS COPPER, DIELECTRIC FITTINGS ARE REQUIRED AT THE CURB BOX.
- 8. STATIONS, OFFSETS, & ELEVATIONS SHALL BE PROVIDED FOR EACH HYDRANT AND TEE.
- 9. PCWR INSPECTION STAFF TO REVIEW TAPPING SLEEVE PRIOR TO TAPPING WATER MAIN.



TYPICAL SERVICE CONNECTIONS
2" OR SMALLER

04-01-2023 APPROVED DATE WS-3